A FRAMATOME ANP

Advanced Mark-BW Mechanical Design Topical NRC and Framatome ANP

June 18, 2002

Framatome ANP Non-Proprietary



OVERVIEW

- > Advanced Mark-BW Design Features
- > Mark-BW Operating Experience
- > Advanced Mark-BW LTA Program
- > Design Evaluation
- > Conclusions




Mark-BW to Advanced Mark-BW Design Evolution


- > Features implemented on a plant-specific basis since the NRC review and approval of BAW-10172P
 - Debris filter bottom nozzle
 - Reduction in number of grid restraining guide thimbles from 12 to 8
 - Low pressure drop top nozzle
- > Features related to the use of M5 material that were reviewed and approved by the NRC in BAW-10227P-A
 - M5 fuel rod cladding
 - M5 guide thimbles
 - M5 instrument tube sheath
 - M5 intermediate grids

- > Features that are new and specific to the Advanced Mark-BW design
 - M5 Mid-span mixing grids (MSMGs)
 - Quick disconnect (QD) top nozzle connection

Advanced Mark-BW Design Features




Advanced Mark-BW (17x17) Top Nozzle



erme is the SALF relation because making the mass.


- > Design Features
 - Low pressure drop
 - Optimized Inconel 718 leaf springs
 - Inconel 718 clamp screws
- > U.S. Operational History
 - Introduced February 2000



- > Standard supply in France
- > QD connection features verified with LTA program



TRAPPER™ Bottom Nozzle




केर्यान्त्रहरूको संबुधि अस्तुवातास्य स्थानाम विभागति अस्ति।

- > Provides superior debris protection
 - No debris failures since introduction
 - Pressure drop equivalent to traditional debris filters
- > U.S. Operational History
 - Introduced in January 1996

> Standard supply in France

Mark-BW (17x17) Structural Grids



Inconel 718 End Grid Assembly


> U.S. Operational History

trom-cologsidiested jakedeleiniebiogsideteleine-


■ End grid and intermediate grids introduced in original Mark-BW design in 1987

- M5 grid is same grid as zircaloy 4 grid
- Basically same material properties
- Low corrosion

M5 Intermediate Grid



Mark-BW (17x17) Intermediate Grid Features




Grid Details (Including Restraint Features)


interes vivi

- High CHF performance
- Floating intermediate grids
- Keyed spacer grids


Inner Grid Strip Features



Mark-BW (17x17) Intermediate Grid Restraint



Intermediate Grid Restraining GT Locations •




- > Grid restraint design remains unchanged since 1992
 - Number of grid restraint guide thimble locations reduced from 12 to 8


ारणात्म्यकार्वे विद्याच्या स्थापित स्थापात्म । स्थापात्म स्थापात्म स्थापात्म स्थापात्म स्थापात्म स्थापात्म स्थ

Mid-span Mixing Grids Restraining GT Locations 🖸




Mark-BW (17x17) End Grid Restraint





Mark-BW (17x17) Mid-Span Mixing Grid




- > MSMG verified with LTA program
- > CHF performance topical approved
 - BAW-10199P-A Addendum 2


A FRAMATOME AND

Mark-BW (17x17) MSMG Details

-ชิดเกิระสรีรัตสานีใช้โดงกฤทเลยชี้มีราญ-ชิทูตลัยใหม่เกิร



Advanced Mark-BW (17x17) Guide Thimble Assembly



- > Same guide thimble dimensions
- Incorporates Quick Disconnect (QD) features
- > QD sleeve material is 304L
 - Not susceptible to stress corrosion cracking
 - Fabrication process does not introduce heat source to sensitize material



Advanced Mark-BW (17x17) Fuel Rod


pronecesting will testomical devige malausticings.


Fuel Rod Parameters	Mark-BW	Advanced Mark-BW
Clad Material	SRA Zircaloy-4 or	M5 Alloy
	M5 Alloy	
Fuel Rod Length, in	151.80	152.16
Cladding OD, in	0.374	0.374
Cladding Thickness, in	0.024	0.0225
Cladding ID, in	0.326	0.329
Clad-to-Pellet Gap, in	0.0065	0.0065
Fuel Pellet OD, in	0.3195	0.3225
Plenum Springs	Top and Bottom	Тор





Mark-BW Fuel Operating Experience











Lead Test Assembly Program



Lead Test Assembly Program

> Advanced Mark-BW/X1 - North Anna

Objectives


- Confirm operating performance of design features (MSMG's and Quick Disconnect Top Nozzle)
- Provide high/extended burnupp data on M5TM

■ Scope/Status

hermage Intelligitation of the particular Marina

- 4 LTAs successfully completed 3-18 month cycles of irradiation in North Anna 1 (56.6 GWd/mtU rod burnup)
- PIE completed January 2002
- Scheduled for re-insertion for a fourth cycle in North Anna 2
- PIE Fall 2004
 - ~73 GWd/mtU fuel rod burnup
- Potential Hot Cell
 - 2003 (3 cycles)
 - 2005-2006 (4 cycles)





LTA Summary

- > After three cycles of irradiation in North Anna unit 1, the Advanced Mk-BW lead assemblies performed exceptionally well
- > Low axidation, growth and deformation evaluations indicate that a fourth cycle of exposure is easily accommodated



Design Evaluation



- > Demonstrates that the fuel assembly satisfies the requirements outlined in Section 4.2 of the Standard Review Plan, NUREG-0800
- > Fuel System Damage Criteria
 - Stress Criterion:
 - Stress intensities for Advanced Mark-BW fuel assembly components shall be less than the stress limits based on American Society of Mechanical Engineers (ASME) Code, Section III criteria.
 - The following fuel assembly components were evaluated:
 - Guide thimble assembly
 - Top and bottom nozzles
 - Grids/grid restraint
 - Quick disconnect
 - Holddown spring assembly
 - Instrument sheath

evanie aktore eitle verdaansgestetop voorsteteams-

Positive margins were determined for all fuel assembly structural components

A FRAMATOME AND

>Fuel System Damage Criteria

- Fuel Rod Cladding Stress Criterion:
 - Fuel rod cladding stress shall not exceed stress limits established in BAW-10227P-A, Evaluation of Advanced Cladding and Structural Material (M5) in PWR Reactor Fuel
 - Pm < 1.5 Sm in compression and < Sm in tension
 - Pm + Pb < 1.5 Sm
 - Pm + Pb + Pl < 1.5 Sm
 - Pm + Pb + Pl + Q < 3.0 Sm
- · Types of stresses evaluated
 - Pressure (Pm)
 - Flow-induced vibration (Pb)
 - Ovality (Pb)
 - Thermal (Q)
 - Fuel rod growth (slip loads) (Q)
 - Three-point grid stop bending stresses (Pb)
 - Fuel rod spacer grid interaction (PI)
- Positive margins were determined for fuel rod cladding stresses

nomeriklerebilkledimmedelelegeingebilele

1000 18 A 1000

Advanced Mark-BW Design Evaluation Advanced Mark-BW Fuel Rod Stress Result Summary

>Fuel System Damage Criteria

Cladding Strain Criterion:

ingqueste sage with scaling of the way to great staying

- The Advanced Mark-BW fuel rod transient strain limit is 1% for Conditions I and II events per BAW-10227P-A, *Evaluation of Advanced Cladding and Structural Material (M5) in PWR Reactor Fuel.*
- Analysis conducted using BAW-10162P-A, TACO3 Fuel Pin Analysis Computer Code
- Calculated Linear Heat Rates for transients that result in 1% cladding strain are not limiting to plant operation



>Fuel System Damage Criteria

- Cladding Fatigue Criterion:
 - The maximum fuel rod fatigue usage factor is 0.9.
- Analyzed per BAW-10227P-A, Evaluation of Advanced Cladding and Structural Material (M5) in PWR Reactor Fuel.
- Assumed 8 year fuel rod life

the anneal of the field of the land of the conference of the confe

Calculated fatigue usage factor

>Fuel System Damage Criteria

- Fretting Criterion
 - Span average cross flow velocities shall be less than 2 ft/sec
- Criterion precludes unacceptable FIV
- Mixed-core evaluations with resident fuel with and without MSMGs
- Models show small FIV amplitudes
 - Benchmark well with FIV tests



- >Fuel System Damage Criteria
 - Fretting Criterion
 - Fuel assembly design shall be shown to provide sufficient support to limit fuel rod vibration and clad fretting wear.
 - Extensive out-of-core testing
 - 1000 hour endurance testing @ reactor conditions
 - 0.001 inch comparable with other proven designs
 - Dual loop FIV flow testingLess than microns rms amplitude
 - Successful 3 cycle LTA program (~57 GWd/mtÚ)
 - Included core periphery locations
 - Utilize proven Mark-BW grid designs

 failures in over rods since 1993 (only fretting)

 No failures in fuel assemblies with reactors

>Fuel System Damage Criteria

tormesi Innedi Inganiyak siguingan kenis anak 1002

- Oxidation, Hydriding, and Crud Buildup Criterion
 - The fuel rod cladding best-estimate corrosion shall be less than 100 microns per BAW-10186P-A.
 - Hydrogen pickup is controlled by the corrosion limit.
- Predicted M5 maximum corrosion microns
- Predicted M5 maximum hydrogen content [] ppm at 65 GWd/mtU



>Fuel System Damage Criteria

- Fuel Rod Bow Criterion
 - Fuel rod bow is evaluated with respect to the mechanical and thermal-hydraulic performance of the fuel assembly. There is no specific design criterion for fuel rod bow.
- Use of Mark-BW features consistent with existing performance data
 - New data per BAW-10186P Revision 1 Supplement 1, *Mark-BW Extended Burnup* extends rod bow database to GWd/mtU
- LTA water channel confirms rod bow characteristics
- Rod bow correlations per BAW-10147P-A Revision 1, Fuel Rod Bowing in Babcock & Wilcox Fuel Designs remain applicable



>Fuel System Damage Criteria

• Axial Growth Criterion

विद्यान्त्रहर्गिताः वर्गिदेशियन्। वात्रन्ति । अवस्य विद्यालयो । स्टियान्

- Fuel assembly to reactor internals gap allowance shall be designed to provide positive clearance during assembly lifetime.
- Maximum M5 rod burnup 62,000 MWd/mtU
- Maximum fuel assembly burnup of 60,000 MWd/mtU
- Growth models per BAW-10227P-A, Evaluation of Advanced Cladding and Structural Material (M5) in PWR Reactor Fuel
- Inch worst case gap (cold) very conservative given low growth FA data



>Fuel System Damage Criteria

- Axial Growth Criterion
 - The fuel assembly top nozzle-to-fuel rod gap allowance shall be designed to provide positive clearance during the assembly lifetime.
- Maximum M5 rod burnup 65,000 MWd/mtU
- Maximum M5 fuel rod growth
- No fuel assembly growth
- []inch worst case gap (hot)



- >Fuel System Damage Criteria
 - Fuel Rod Internal Pressure
 - The fuel system shall not be damaged due to excessive internal pressure.
 - Limited to that which would cause the diametral gap to increase due to outward creep during steady-state operation
 - Extensive DNB propagation to occur
 - Fuel rod internal pressure methodology established per BAW-10183P-A, Fuel Rod Gas Pressure Criterion (FRGPC).
 - Internal gas pressure determined using NRC-approved TACO 3 code per BAW-10162P-A
 - Fuel rod internal pressure shown to be acceptable for maximum burnup of 62 GWd/mtU
 - Other NRC approved codes such as COPERNIC per BAW-10231P-A, COPERNIC Fuel Rod Design Computer Code may bed utilized in future evaluations

confession to the configuration of the configuration of the confession of the confes

>Fuel System Damage Criteria

Assembly Liftoff

connected of Figure Connected Annual Control Strainty

- The fuel assembly holddown springs must be capable of maintaining fuel assembly contact with the lower support plate during normal operation, Conditions I and II events, except for pump overspeed transient.
- The fuel assembly shall not compress the holddown spring to solid height for any Condition I and II event.
- The fuel assembly top and bottom nozzles shall maintain engagement with reactor internals for all Condition I thru IV events.
- Hydraulic lift forces determined using the LYNXT code per BAW-10156P-A Revision 1, LYNXT: Core Transient Thermal-Hydraulic Program
 - Full core and mixed core configurations considered
- Fuel assembly shown to be acceptable



>Fuel Rod Failure Criteria

- Internal Hydriding
 - Internal hydriding shall be precluded by appropriate manufacturing controls.
- Precluded by manufacturing controls
- Fabrication limit ppm hydrogen
- Cladding Collapse

<u> Income a Montalit Malcome de De (que l'objecut Mallos</u>

- The predicted creep collapse life of the fuel rod must exceed the expected in-core life
- Evaluated per BAW-10084P-A, Program to Determine In-Reactor Performance of BWFC Fuel Cladding Creep Collapse
- M5 creep rate is
 that of zircaloy-4
- Creep collapse life greater than 62 GWd/mtU



>Fuel Rod Failure Criteria

Liver of Markin Seamont Language and Maring

- Overheating of Cladding
 - For a 95% probability at a 95% confidence level, DNB shall not occur for normal operation and anticipated operational occurrences (AOOs)
- Addressed in plant specific transient analyses with NRC approved methods
 - BAW-10199P-A Addendum 2, Application of the BWU-Z CHF Correlation to the Mark-BW17 Fuel Design with Mid-Span Mixing Grids



>Fuel Rod Failure Criteria

- Overheating of Fuel Pellets
 - For a 95% probability at a 95% confidence level, fuel pellet centerline melting shall not occur for normal operation and anticipated operational occurrences (AOOs)
- NRC-approved TACO 3 code per BAW-10162P-A used to determine local LHR throughout rod life such that pellet centerline temperature meets criterion
- Typical generic centerline fuel melt limit is kW/ft
- Pellet Cladding Interaction
 - No generally applicable criteria
 - Clad strain and fuel melt criteria are used
- Cladding Rupture
 - Addressed in plant-specific LOCA analyses using NRC-approved methods



>Fuel Coolability

ા કરવામાં આ મામ કરવામાં આ માટે કરવા

- Cladding Embrittlement
 - Addressed in plant-specific LOCA analyses using NRCapproved methods
- Violent Expulsion
 - Addressed in plant-specific safety analyses using NRCapproved methods
- Fuel Rod Ballooning
 - Addressed in plant-specific safety analyses using NRCapproved methods

A FRAMATOME AND

- >Fuel Coolability
 - <u>Fuel Assembly Structural Damage from External Forces Cladding</u> <u>Embrittlement</u>
 - Operational Base Earthquake (OBE) Allow continued safe operation of fuel assembly following an OBE event by ensuring that the FA components do not violate their dimensional requirements
 - Safe Shutdown Earthquake (SSE) Ensure safe shutdown of reactor by maintaining overall structural integrity of FAs, control rod insertability, and a coolable geometry within the deformation limits consistent with the Emergency Core Cooling (ECCS) and safety analysis
 - LOCA or SSE+LOCA Ensure safe shutdown of reactor by maintaining overall structural integrity of FAs and a coolable geometry within deformation limits consistent with ECCS and safety analysis



>Fuel Coolability

- Horizontal analysis
 - Models and methods per BAW-10133P-A Revision 1 Addendum 1, Mark-C Fuel Assembly LOCA-Seismic Analyses
 - · Core models

instance of Anglish is Marian and assign in project Marias

- 3 to 15 FA rows
- Full core Advanced Mark-BW
- Mixed core of Advanced Mark-BW and resident fuel
- Worst-case attached pipe break loadings based on leak-beforebreak

A FRAMATOME AND

>Fuel Coolability

ंबर्कान्य १००४ वर्षे ४ १८५ को स्वर्धे के क्षेत्र का का का किए है।

- Horizontal analysis results
 - Maximum grid impact loads at peripheral FA locations for shortest row
 - OBE and SSE loads within elastic limits
 - Intermediate grids –MSMGs –
 - LOCA and SSE+LOCA
 - Grid deformation evaluation maintains core coolable geometry
 - Intermediate grid -MSMG -
 - Maximum grid impact loads for all interior FA locations remain within elastic limits for all faulted conditions



>Fuel Coolability

promise for sure designations of the first promise of the first pro-

- Vertical analysis
 - Vertical loading analysis methodology per BAW-10133P-A Revision 1
 - Bounding attached pipe breaks based on leak-before-break
 - Guide thimble loads well below allowable buckling load limits for rod insertability

>Conclusion

- Advanced Mark-BW fuel assembly meets all fuel assembly design criteria critical to safe and reliable operation.
- The standard Mark-BW features maintained in the Advanced Mark-BW assembly provide reactor-proven design parameters that provide a basis for successful future performance.
- Design verification testing and analyses have demonstrated the acceptability of the added design features and ensure that the Advanced Mark-BW fuel assembly will operate safely and reliably.
- A detailed LTA program further verified the Advanced Mark-BW irradiation performance.
- Acceptable Advanced Mark-BW fuel assembly and fuel rod mechanical and thermal-hydraulic performance capability can be obtained for fuel rod burnups up to 62,000 MWd/MTU.

Commented Control of State Control of TRAMATOME AND